





Technical Report No.: 64.181.22.03623.01 Rev.01

Date: 2023-09-04

Client: Name: Guangzhou Hiseer Air Conditioning Co.,Ltd

Address: Xicheng industry zone, Renhe town, Baiyun district,

Guangzhou China

Contact person: YAN Wei

Manufacturer: Name: Guangzhou Hiseer Air Conditioning Co.,Ltd

Address: Xicheng industry zone, Renhe town, Baiyun district,

Guangzhou China

Factory: Name: Guangzhou Hiseer Air Conditioning Co.,Ltd

Address: Xicheng industry zone, Renhe town, Baiyun district,

Guangzhou China

Test object: Product: Inverter Air source heat pump

Model: RS10V/L

Trade mark: Hiseer

☑ EN 14511-3:2022

☑ EN 12102-1:2022

Purpose of Test according to the test specification

examination:

☑ (EU) No 813/2013

EU 2016/2282:2016-11-30

PPP 18025B:2022

Test result: The test results show that the presented product is in compliance with the above

listed test specifications.

Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question. It does not imply a general statement regarding the quality of products from regular production. For further details please see testing and certification regulation, chapter A-3.4.

www.tuvsud.com

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04

Date: 2023-09-04 Page: 1 of 18

TÜV®

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



#### 1 Description of the test object

#### 1.1 **Function**

Manufacturer's specification for intended use:

The appliance is air to water heat pump.

Manufacturer's specification for predictive use:

	According to user manual	
1.2	Consideration of the foresee  Not applicable Covered through the applied Covered by the following com Covered by attached risk and	standard nment
1.3	Technical Data  Model: Rated Voltage (V): Rated Frequency (Hz): Rated Power (W): Rated Current (A): Protection Class: Protection Against Moisture:	RS10V/L 380-415V, 3N~ 50 3700+4000 (Auxiliary heater) 16.0 Class I IP X4
	Construction : Supply connection :	Stationary  Non detachable cord  Permanent connection to fixed wiring
	Operation mode:	Continuous operation;

Declared parameters: **✓** Sound power level dB(A):

Refrigerant/charge (kg):

Series No: SHSBW2209002 for RS10V/L

Doc No.: ITC-TTW0902.02E - Rev.13

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 2 of 18

Intermittent operation; Short time operation;

Warmer

R32 /1.8 kg

Average

Guangzhou Branch 5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China

TÜV SÜD Certification and Testing (China) Co., Ltd.

Colder



#### 2 Order

### 2.1 Date of Purchase Order, Customer's Reference

Date of Purchase Order: 2022-06-30, 2023-03-01, 2023-06-02, 2023-08-22

Customer's Reference: Guangzhou Hiseer Air Conditioning Co., Ltd

#### 2.2 Test Sample(s)

• Reception date(s): 2022-03-04, 2022-08-17, 2023-04-05

• Location(s) of reception:

For Energy test:

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

B1F&2F, No. 3 Chuangqi Building, No. 63 Chuangqi Road, Shilou Town, Panyu District,

Guangzhou 511447, China

For Noise tests:

For Noise tests: (Reception date(s): 2022-08-18)

The test item is not in accredited scope of our own laboratory (Registration No. CNAS L3584). It was subcontracted to an accredited laboratory with CNAS certificate No. CNAS L0095.

Address: No.3, Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, P.R.China

• Condition of test sample(s): completed and can be normal operation

### 2.3 Date(s) of Testing

2022-08-24 to 2022-10-15, 2023-06-05 to 2023-07-01

#### 2.4 Location(s) of Testing

Same as 2.2

### 2.5 Points of Non-compliance or Exceptions of the Test Procedure

N/A

#### 3 Test Results

☑ Decision rule according to ILAC-G8:09/2019 clause 4.2.1 Binary statement for simple acceptance rule or IEC Guide 115:2023, clause 4.3 Simple acceptance was applied. ☐ Decision rule according to systematic was applied. It is:
☐ Decision rule according to customer's requirements was applied. It is:
□ Decision rule according to ILAC-G8:09/2019 clause 4.2.2 Binary statement with guard band -
guard band length = 95 % extended measurement uncertainty, was applied.
□ Decision rule (based on ILAC-G8:09/2019 clause 4.2.3 Non-binary statement with guard band,
guard band length = 95 % extended measurement uncertainty) for an upper specification limit (A lower limit or specification with an up-per and a lower limit is treated similarly.):
•Compliance with the requirement: If a specification limit is not breached by a measurement
result plus the expanded uncertainty with a 95% coverage probability, then compliance with the specification will be stated (e. g. Pass).
•Non-compliance with the requirement: If a specification limit is exceeded by the measurement
result minus the expanded uncertainty with a 95% coverage probability, then non-compliance with the specification will be stated (e. g. Fail).
•Inconclusive result: If a measurement result plus/minus the expanded uncertainty with a 95 %
coverage probability overlaps the limit it will be stated that it is not possible to state compliance or

 $\Box$  There are no statements to conformity or no results with measurand stated in this report, no decision rule has been applied.

www.tuvsud.com

Project No: 64.181.22.03623.01

non-compliance.

Rev.: 01 Date: 2023-09-04 Page: 3 of 18

TÜV®

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



#### 3.1 Positive Test Results

See Appendix I

#### 4 Remarks

#### 4.1 General

The user manual has been examined according to the minimum requirements described in the product standard. The manufacturer is responsible for the accuracy of further par-ticulars as well as of the composition and layout.

**4.2** When the product is placed on the market, it must be accompanied with safety Instructions written in official language of the country. The instructions shall give information re-garding safe operation, installation and maintenance.

#### 5 Documentation

· Appendix I: Test results

· Appendix II: Marking plate

· Appendix III: photo documentation

· Appendix IV: Construction data form

· Appendix V: Test equipment list

#### 6 Test History

- The appliance is air to water heat pump, including a whole compression type refrigerant circuit to heat water in another circuit. The appliance was for cooling and heating water function, this report only for heating capacity test.
- 2) The main power is supplied by a 5-pole supply cord connecting to fixed wiring.
- 3) Water enthalpy method was adopted in this report.
- 4) Standby mode power, off mode power and thermostat-off mode power were tested according to clause 12 of standard EN 14825:2022.
- 5) The test report 64.181.22.03623.01 Rev.01, dated 2023-09-04, replace original report 64.181.22.03623.01 Rev.00, dated 2022-10-17, and based on test report 64.181.22.03018.01 Rev.01, dated 2023-08-04 to include the following changes and/or additions, which were considered technical modifications:
  - a) Changing report holder name and address, manufacturer and factory's name and address.
  - b) After evaluating, no additional test was needed.

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch TÜV SÜD Group

Tested by: Plum Li, Project Handler

printed name, function & signature

Approved by: Gary Sun, Designated Reviewe

printed name, function & signature

www.tuvsud.com

Rev.: 01 Date: 2023-09-04 Page: 4 of 18

Project No: 64.181.22.03623.01

TÜV®

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China

Tel: +86 20 38320668

TING (CHINA





Table 1.	Heating mod	ı	P				
Model	RS10V/L						
Product type	Air to Water	Heating season	✓ Average	□ W	armer	Colder	
1. Test condi	tions:	-		•	<u>.</u>	-	
	F	Part Load Ra	ntio		tdoor		r heat
Condition	Form	in %	Average		(changer		anger let water
	Foili	iuia	Average climates		(wet) bulb ature (°C)		tures (°C)
А	(-7-16)/(Tde	esignh-16)	88	-7	<b>'</b> (-8)	a /	34
В	(+2-16)/ (Td	esignh-16)	54	2	2(1)	a /	30
С	(+7-16)/(Td	esignh-16)	35	7	<b>'</b> (6)	a /	27
D	(+12-16)/(To	lesignh-16)	15	12	2(11)	a /	24
Е	(TOL	16)/ (Tdesig	nh-16)	Т	OL	a / 35.3	
F	(Tbival	ent-16)/(Tde:	signh-16)	Tbiv		a / 34	
G	(-15-16)/(Td	esignh-16)	N/A	-15		N/A	
conditions, the c		-		, the COP is 4	.46kW/kW.		
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)	A2/W30 (54%)	A7/W27 (35%)	A12/W24 (15%)	A(-10)/ W35.3 (100%)	A(-7)/ W34 (88%)
		Α	В	С	D	Е	F
Data collection period	hh: min:sec	3:00:00	1:10:00	1:10:00	1:10:00	3:00:00	3:00:00
The heat pump defrosts		Yes	No	No	No	Yes	Yes
Electrical Prop	erties						
Voltage	V	399.9	400.3	398.8	398.8	399.9	399.9
Current input of the unit	А	4.56	1.86	1.24	1.08	4.66	4.56
Power input of the unit	kW	2.934	1.242	0.804	0.694	3.004	2.934
Compressor frequency	Hz	95	43	30	30	95	95

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 5 of 18 www.tuvsud.com





S User Side							
m³/h	1.56	1.56	1.56	1.56	1.56	1.56	
°C	28.74	27.16	25.24	23.29	30.38	28.74	
°C	33.49*	30.06	27.59	25.96	34.95	33.49*	
Source Side	,						
kPa	101.02	101.01	101.04	101.02	101.03	101.02	
°C	-6.95	2.00	7.00	12.00	-9.91	-6.95	
°C	-7.99	0.99	6.00	10.99	-10.93	-7.99	
WB Summary of the results							
kW	8.497	5.182	4.197	4.782	8.168	8.497	
kW	2.825	1.173	0.739	0.626	2.899	2.825	
kW/kW	3.01	4.42	5.68	7.64	2.82	3.01	
	m³/h °C °C s Source Side kPa °C °C c results kW	m³/h 1.56  °C 28.74  °C 33.49*  S Source Side  kPa 101.02  °C -6.95  °C -7.99  e results  kW 8.497  kW 2.825	m³/h       1.56       1.56         °C       28.74       27.16         °C       33.49*       30.06         Source Side         kPa       101.02       101.01         °C       -6.95       2.00         °C       -7.99       0.99         e results       kW       8.497       5.182         kW       2.825       1.173	m³/h       1.56       1.56       1.56         °C       28.74       27.16       25.24         °C       33.49*       30.06       27.59         Source Side         kPa       101.02       101.01       101.04         °C       -6.95       2.00       7.00         °C       -7.99       0.99       6.00         e results         kW       8.497       5.182       4.197         kW       2.825       1.173       0.739	m³/h       1.56       1.56       1.56       1.56         °C       28.74       27.16       25.24       23.29         °C       33.49*       30.06       27.59       25.96         Source Side         kPa       101.02       101.01       101.04       101.02         °C       -6.95       2.00       7.00       12.00         °C       -7.99       0.99       6.00       10.99         e results         kW       8.497       5.182       4.197       4.782         kW       2.825       1.173       0.739       0.626	m³/h 1.56 1.56 1.56 1.56 1.56 1.56  °C 28.74 27.16 25.24 23.29 30.38  °C 33.49* 30.06 27.59 25.96 34.95  S Source Side  kPa 101.02 101.01 101.04 101.02 101.03  °C -6.95 2.00 7.00 12.00 -9.91  °C -7.99 0.99 6.00 10.99 -10.93  e results  kW 8.497 5.182 4.197 4.782 8.168  kW 2.825 1.173 0.739 0.626 2.899	

Electric power consumptions	Unit	Value
Thermostat-off mode [P <sub>TO</sub> ]	kW	0.016
Standby mode [P <sub>SB</sub> ]	kW	0.016
Crankcase heater [P <sub>CK</sub> ]	kW	0.000
Off mode [P <sub>OFF</sub> ]	kW	0.016

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 6 of 18  $\underline{www.tuvsud.com}$ 



3.Calculation/conclusion for SCOP :								
Tdesignh(°C):	-10		Tbiv(°C):	-7				
Pdesignh(kW):	9.605		TOL(°C):	-10				
Test result A, B, C, D, E, F conditions:								
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load		
E	9.605	8.168	2.82	0.00	1.00	2.82		
F	8.497	8.497	3.01	0.00	1.00	3.01		
А	8.497	8.497	3.01	0.00	1.00	3.01		
В	5.172	5.182	4.42	0.00	1.00	4.42		
С	3.325	4.197	5.68	0.99	0.79	5.66		
D	1.478	4.782	7.64	0.99	0.31	7.47		
CR: part load divided by capacity;								

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	4.55
SCOP:	kWh/kWh	4.54
Q <sub>H</sub> :	kWh/year	19844
Q <sub>HE</sub> :	kWh/year	4367
$\eta_{s,h}$	%	178.7
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)		A+++

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 7 of 18 www.tuvsud.com

TI"N/®





Table 2.	Heating mode (Medium temperature application):								P	
Model	RS10V/L								•	
Product type	Air to Water	Heating season	✓ Aver	age		Warr	mer		Colder	
1. Test condi	tions:									
	F	Part Load Ra	ntio			Outdo				r heat
Condition	Form	in %	Λιανοσ			at excl				anger
	FOIII	iuia	Average climates			dry (w nperati	,			let water tures (°C)
А	(-7-16)/(Tde	esignh-16)	88			-7(-8	3)		a /	52
В	(+2-16)/ (Td	esignh-16)	54			2(1	)		a /	42
С	(+7-16)/(Td	esignh-16)	35			7(6	)		a /	36
D	(+12-16)/(To	lesignh-16)	15			12(1	1)		a /	30
Е	(TOL	₋-16)/ (Tdesio	gnh-16)			TOI	L		a / 55.3	
F	(Tbival	ent-16)/(Tde	signh-16)		Tbiv		a / 52			
G	(-15-16)/(Td	esignh-16)	N/A		-15		N/A			
Remark: a) With conditions, the conditions.	capacity is 9.95	54kW, the po	wer is 3.307							
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)	A2/W42 (54%)	2	A7/W3 (35%)			W30 5%)	A(-10)/ W55.3 (100%)	A(-7)/ W52 (88%)
		А	В		С		[	)	Е	F
Data collection period	hh: min:sec	3:00:00	1:10:00	)	1:10:0	0	1:10	0:00	1:10:00	3:00:00
The heat pump defrosts		Yes	No		No		N	lo	No	Yes
Electrical Prop	erties					•				
Voltage	V	399.3	400.3		398.7	7	39	8.8	399.3	399.3
Current input of the unit	А	5.78	2.52		1.56		1.	33	5.94	5.78
Power input of the unit	kW	3.916	1.707		1.028	3	0.8	376	4.028	3.916
Compressor frequency	Hz	95	48		30		3	0	93	95

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 8 of 18

www.tuvsud.com





Test conditions	Test conditions User Side							
Water flow	m³/h	1.09	1.09	1.09	1.09	1.09	1.09	
Inlet Water temperature	°C	4.48	37.61	33.21	28.75	48.16	4.48	
Outlet Water temperature	°C	51.63	42.01	36.42	32.44	55.08	51.63	
Test conditions	s Source Side	,						
Barometric pressure	kPa	101.03	101.05	101.10	101.09	101.04	101.03	
Air <b>inlet</b> temperature, DB	°C	-6.96	2.01	7.00	12.00	-10.00	-6.96	
Air <b>inlet</b> temperature, WB	°C	-8.00	1.01	6.00	11.01	-11.01	-8.00	
Summary of the results								
Total heating capacity	kW	8.903	5.491	4.004	4.611	8.602	8.903	
Effective power input	kW	3.848	1.639	0.960	0.810	3.954	3.848	
Coefficient of performance (COP)	kW/kW	2.31	3.35	4.17	5.69	2.18	2.31	

Electric power consumptions	Unit	Value
Thermostat-off mode [P <sub>TO</sub> ]	kW	0.015
Standby mode [P <sub>SB</sub> ]	kW	0.014
Crankcase heater [P <sub>CK</sub> ]	kW	0.000
Off mode [P <sub>OFF</sub> ]	kW	0.014

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 9 of 18  $\underline{www.tuvsud.com}$ 





3.Calculation/conclusion for SCOP:								
Tdesignh(°C):	-10		Tbiv(°C):	-7				
Pdesignh(kW):	10.064		TOL(°C):	-10				
Test result A, B, C, D, E, F conditions:								
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load		
E	10.064	8.602	2.18	0.00	1.00	2.18		
F	8.903	8.903	2.31	0.00	1.00	2.31		
А	8.903	8.903	2.31	0.00	1.00	2.31		
В	5.419	5.491	3.35	0.00	0.99	3.35		
С	3.484	4.004	4.17	0.99	0.87	4.16		
D	1.548	4.611	5.69	0.99	0.34	5.58		

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	3.44
SCOP:	kWh/kWh	3.44
Q <sub>H</sub> :	kWh/year	20792
Q <sub>HE</sub> :	kWh/year	6053
$\eta_{s,h}$	%	134.4
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)		A++

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 10 of 18  $\underline{www.tuvsud.com}$ 

ΠÜV<sup>®</sup>



Sound power level	Р			
RS10V/L				
Product type :			Air to Water	
Outdoor heat exchar	Outdoor heat exchanger, Air temperature DB/WB (°C):			
Indoor heat exchang	er, Water inlet/outlet t	emperature (°C):	47.0 /55.0	
Voltage (V):		399.2		
Frequency (Hz): Working condition class :				
				Acoustical environm
Windshield type :			Sponge	
Measured position a	mount :	14		
Water flow (m³/h):	ater flow (m³/h):			
sured quantity	L <sub>WA,indoors</sub> (dB(A))	L <sub>WA,outdoors</sub> (dB(A))	Remark	
ure level $\bar{L}_{p(ST)}^{****}$		49		
nt radius r *		1.0m		
r level L <sub>wA</sub> ****		64		
	RS10V/L  Product type:  Outdoor heat exchang  Voltage (V):  Frequency (Hz):  Working condition cl  Acoustical environm  Windshield type:  Measured position a  Water flow (m³/h):  sured quantity  ure level $\overline{L}_{p(ST)}^{*****}$ at radius r *	RS10V/L  Product type:  Outdoor heat exchanger, Air temperature I  Indoor heat exchanger, Water inlet/outlet to  Voltage (V):  Frequency (Hz):  Working condition class:  Acoustical environment:  Windshield type:  Measured position amount:  Water flow (m³/h):  Sured quantity  Ure level Lp(ST)****  Tradius r*	Product type:  Outdoor heat exchanger, Air temperature DB/WB (°C):  Indoor heat exchanger, Water inlet/outlet temperature (°C):  Voltage (V):  Frequency (Hz):  Working condition class:  Acoustical environment:  Windshield type:  Measured position amount:  Water flow (m³/h):  Sured quantity  LwA,indoors (dB(A))  LwA,outdoors (dB(A))  ure level \( \bar{L}_{p(ST)}^{****} \)  49  1.0m	

Setting of controls: according to user manual.

Duct connection:--

Rounding to: \*) 1 decimal places; \*\*\*) 2 decimal places; \*\*\*\*) 3 decimal places; \*\*\*\*) nearest integer

Fan speed: 598 r/min, compressor speed: 70Hz.

Doc No.: ITC-TTW0902.02E - Rev.13

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 11 of 18







Table 5.	. Clause 4 of EN 14511-4:2022	
Model:	RS10V/L	
TEST 1	STARTING TEST (§4.2.1.2 Table 3)	

Requirement: The "lower" starting operating conditions declared by the manufacturer for the heating mode- i.e. Tair=-25.02°C, T in water = 21.91°C, Flow rate 1,18m³/h have been set and obtained. At those conditions, the machine was switched on.

Observation/ Evaluation: It started without any problem and worked for 30 minutes without showing any warning or alarm. During the test the machine operated in auto mode. No damage was recorded on the machine during and after the test.

Test Response: Pass

### TEST 2 OPERATING TEST (§4.2.1.2 Table 3)

Requirement: From the machine "lower" starting conditions - i.e. - the machine was brought to the lower operating conditions declared by the manufacturer for the heating mode- i.e. Tair=-25.00°C, T in water = 38.8° C, Flow rate 1.21m³/h. Once these conditions were obtained, the machine was let operate for over 1 hour in auto mode.

Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.

Test Response: Pass

# TEST 3 SHUTTING OFF WATER FLOW (§ 4.5)

Requirement: The water flow rate was shuted off through manual and automatic valves of the test rig. The machine switched off and only the flow switch Protection appeared on the user interface of indoor unit.

Observation/ Evaluation: Perform error reset operation, once the water flow rate was restored, the machine restarted automatically and worked for 30 minutes normally. No damage was recorded on the machine during and after the test.

Test Response: Pass

## TEST 4 SHUTTING OFF AIR FLOW (§ 4.5)

Requirement: The air flow rate was shutted off through a plastic sheet and a panel. The machine never turned off. It continued to operate with continuous frosting and defrosting cycles. After more than half an hour, the air flow rate was restored and the machine started to operate normally.

Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.

Test Response: Pass

### TEST 5 COMPLETE POWER SUPPLY FAILURE (§ 4.6)

Requirement: The power supply was cut off for about 5 seconds.

Observation/ Evaluation: The unit restarted automatically within about 3 minutes after the power supply was reactivated.

Test Response: Pass

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 12 of 18 www.tuvsud.com



### **Appendix II Marking plate**

#### Nameplate

Model: RS10V/L

# Inverter Air Source Heat Pump

Model: RS10V/L Heating capacity at A7/W35℃: 2.6-10.2 kW Cooling capacity at A35/W7°C: 1.72-6.43 kW Aux. electric heater: 4 kW Power supply: 380-415V/3N~/50Hz Power consumption at A7/W35°C: 0.54-2.46 kW Nominal running current at A7/W35°C: 2.4-10.9 A Power consumption at A35/W7℃: 0.57-2.75 kW Nominal running current at A35/W7°C: 2.6-12.2 A Rated power consumption: 3.7 (7.7) kW Rated operating current: 16 (16) A Refrigerant: R32 Filling weight: 1.8 kg Pipe connector: G1" Anti electric shock grade: IPX4 Water proof grade: Nominal flow heating medium: 1.2-2.0 m<sup>3</sup>/h Max outlet heating medium temperature: 55°C Max. Operation pressure of low side: 2.8MPa Max. Operation pressure of high side: 4.2MPa Max allowable pressure: 4.2MPa Internal pressure drop at nominal flow: 19kPa N.W: 112kg Series No .: Manufacture date:





Importer:xxx

Manufacturer: Guangzhou Hiseer air conditioning Co.,Ltd Xicheng industryzone,Renhe town,Baiyun district,Guangzhou China

# MADE IN CHINA

Remark: -

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 13 of 18 www.tuvsud.com

"®





# Appendix III photo documentaiton

Details of:	Overall view
View:	
☐ General	
☐ Front	
Rear	
Right	
☐ Left	
□ Тор	
☐ Bottom	
	ė.

Details of:	Compressor
View:	
☐ General	Panasonic 9RD220ZAA2J COMPRESSOR C € 0035
Front	DC MOTOR 280V SERIAL NO. R22H F0006859 7975407 R32
☐ Rear ☐ Right	Panasonic Corporation 松下. 万宝 (广州) 圧縮机有限公司 Made in China
☐ Left	Passonic Nanbao Appliances Compressor (Buangzhou) (20. 1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1.1
□ Тор	Danger of Explosion or Fire 有場本 火灾的危险  **Bear protective googles.**  **Let out the gas before brazing.**  **Do not ome unpresoribed ref. & oils 不要用底皮的水溶解。
☐ Bottom	Do not use unprescribed ref. & oils 不養產用級交易等的 Gaution Hot Surface 有 烫伤的 危险 Do not touch with bare hands 这许是我们并不是是 1500 TEAR 2022 VOLUME 1 50L PS 43 Bar IS 1500 TEAR 2022 VOLUME 1 50L PS 43 Bar IS 1500 TEAR 2022 VOLUME 1 50L PS 43 Bar IS 1500 TEAR 2022 VOLUME 1 50L PS 43 Bar IS 1500 TEAR 2022 VOLUME 1 50L PS 43 Bar IS 1500 TEAR 2022 VOLUME 1 50L PS 43 Bar IS 1500 TEAR 2022 TEAR 2022 Compressor (Guangdong, P. R. Quind and Compressor (Guangdo

Project No: 64.181.22.03623.01


Rev.: 01 Date: 2023-

Date: 2023-09-04 Page: 14 of 18  $\underline{www.tuvsud.com}$ 



 $\mbox{T\"{U}V}$   $\mbox{S\"{U}D}$  Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China





# Appendix III photo documentaiton

Panasonic EHDS83BZD 空调音风扇用直流电动机 OCFAN MOTOR FOR AIR-CONDITIONER BP 120 W DC310 V 960 r/min RHKF写进程现公司 Panasonic Motor (Hangzhou) Co.,Ltd.

Details of:	Main Control Board		
View:			
General			
☐ Front			
Rear			
Right	09н007А006		
☐ Left	Honglian 2122		
□ Тор			
Bottom			
	S o S		

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 15 of 18  $\underline{www.tuvsud.com}$ 







# Appendix III photo documentaiton

Details of:	Water Pump
View:	
☐ General	
☐ Front	
☐ Rear	Min. 0.04 2 Max. 0.58 60 1.0
Right	EEL S 0.20 - Part 3 P S 28W 230V - 50Hz IPX4D TF 110
☐ Left	S/N:10000613 Gradua Military A/S Made in France Research Military Section A/S Research
□ Тор	
☐ Bottom	
	State of the state

Project No: 64.181.22.03623.01

Rev.: 01

Date: 2023-09-04 Page: 16 of 18 www.tuvsud.com

 $TUV^{\mathbb{B}}$ 





## **Appendix IV Construction data form**

Part		Technical data		
1. Compressor				
	Manufacture:	Panasonic Wanbao appliances compressor (Guangzhou) Co.,Ltd		
	Type:	9RD220ZAA2J		
	Rated capacity:	8.65kw		
	Serial-number:	N/A		
	Specification:	DC280V; R32		
2. Condenser	+	<u> </u>		
	Manufacture:	Jiangsu Baode Heat-exchanger Equipment Co., Ltd.		
	Type:	HBL40-28D		
	Heat exchanger:	Brazed plate heat exchanger; Plate spacing 1.3mm		
	Dimension(mm):	W X H X D: 119 x 376 x 55 [mm x mm x mm]		
3. Evaporator				
	Manufacture:	Guangzhou Aotai refrigeration equipment co.,ltd		
	Type:	RS11V/L.CH.00		
	Heat exchanger:	Fin spacing 1.8mm; aluminum finned coil heat exchanger		
	Dimension(mm):	W X D X H:779*300*966 [mm x mm x mm]		
4. Fan motor				
	Manufacture:	Hangzhou Panasonic motor co.,ltd		
	Type:	EHDS83BZD		
	Fan type:	3 blades		
	Specification:	DC310E, 120W, 960r/min		
5. Main control bo	pard			
	Manufacture:	Carel electronic (Suzhou) co.,ltd		
	Type:	UP3A02200T3SO		
	Specification:	230VAC; 50/60Hz		
6. Water pump				
	Manufacture:	Grundfos		
	Type:	UPM3K 25-75 130 AZA		
	Specification:	230VAC; 50Hz		

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 17 of 18  $\underline{www.tuvsud.com}$ 



## **Appendix V Equipment List**

No.	Туре	Manufacture	Model	Equipment ID	Calibration Due Date
1	R&A performance measuring system	GEI	5HP	64-1-90-11-004	2023-12-23
2	Anechoic rooms (hemi-anechoic rooms)	NC-036-2	-	Guangzhou Kinte	2023-10-07
3	AC source Supply	YANGHONG	YF-3600	VGDS-0637	2022-11-07
4	6 channel data logger	-	PXI-1033	VGDY-0257	2023-05-20
5	PULSE system	B & K	3660C	VGDY-0184	2023-04-12
6	Calibrator	B & K	4231	HJ-000095	2023-06-30
7	Long steel tape	_	5m	HJ-000150	2023-01-01
8	Temperature measurement system	_	_	NC-036-1	2023-06-07
9	Atmospheric pressure meter	_	_	HJ-000165	2022-11-22
10	Constant temperature water system	B & K	_	VGDS-0448	2023-04-18
11	Windscreen	B & K	WS002-5	_	_

-- End of Report --

Doc No.: ITC-TTW0902.02E - Rev.13

Project No: 64.181.22.03623.01

Rev.: 01 Date: 2023-09-04 Page: 18 of 18

www.tuvsud.com

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China